

May 20, 2011  
ADDENDUM NO. 1  
SENIOR CENTER EXERIOR DOOR IMPROVEMENTS

In accordance with the pre-bid meeting held May 20, 2011, the following modifications are made to the request for bids:

Doors 1 and 2 : replace butt hinges, replace kick plates, push plates and pull handles as indicated, Reuse existing frame, door closer and automatic opener

Door 3: replace butt hinges, install a new 8" X 34 " stainless steel kick plate

Doors 4 and 5: replace butt hinges

Doors 6 and 7: replace frames, weather stripping and thresholds on both doors. Kitchen door rim panic shall be Yale or equivalent and door closer shall be Norton 1601 or equivalent

All remaining specifications are unchanged. Bids remain due by 3:00 p.m., June 2, 2011.

If you have any questions regarding purchasing procedures, please phone the Purchasing Department at (269) 324-9284. If you have any questions regarding the specifications, please contact Barry Bacon, Deputy Director Parks, Recreation, and Property Management at (269) 324-9271.

