



Annual Drinking Water Quality Report

For January 1 - December 31, 2025

The City of Portage provides this Annual Drinking Water Quality Report for review by Portage Water System customers, pursuant to requirements of the Federal "Safe Drinking Water Act." The City of Portage welcomes the opportunity to demonstrate the excellent level of water quality delivered to Portage residents and utility customers.

Portage Water Meets or Exceeds all Federal and State Quality Requirements

The water source for the Portage utility is groundwater from the Kalamazoo-Portage and Schoolcraft aquifers. Aquifers are water bearing formations beneath the surface of the earth that consist of sand and gravel deposited by glacial activity. The city water system uses 19 groundwater wells with pumping capacities ranging from 330 to 3,700 gallons per minute. The water is treated with chlorine, fluoride and phosphate. The city closely monitors the source water and the treated drinking water to ensure that a high level of quality and safety is maintained.

To ensure that tap water is safe to drink, the Environmental Protection Agency (EPA) prescribes regulations that limit the amount of certain contaminants in water provided by public water supplies. Food & Drug Administration regulations establish limits for contaminants in bottled water that provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the United States

Environmental Protection Agency Safe Drinking Water Hotline (800-426-4791) or at <http://www.epa.gov/safewater>.

Veolia, operator of the city sewer and water utilities, routinely monitors for constituents/substances in the drinking water according to federal and state laws. The results of monitoring efforts for the period of January 1 to December 31, 2025 are provided in the table at the end of this report.

All drinking water sources contain naturally occurring levels of dissolved minerals and, in some cases, radioactive material. However, the presence of these minerals in small amounts is not a concern to the health and well-being of Portage utility customers. Substances that may be present in source water include:

- » Microbial substances, such as viruses and bacteria, which may come from septic systems, sewage treatment plants, agricultural livestock operations and wildlife.
- » Inorganic substances, such as salts and metals, can be naturally-occurring or may result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming
- » Pesticides and herbicides may come from a variety of sources such as agriculture, urban stormwater runoff and residential uses.
- » Organic chemical substances, including synthetic and volatile organic chemicals, are by-products of industrial processes, petroleum production, gas stations, urban stormwater runoff and septic systems.
- » Radioactive substances can occur naturally or be the result of oil and gas production or mining activities.

QUESTIONS CONCERNING WATER QUALITY AND OTHER UTILITY SERVICES MAY BE DIRECTED TO THE FOLLOWING PERSONNEL:

Kendra Gwin, P.E.
Director of Transportation & Utilities
City of Portage
7719 South Westnedge Avenue
Portage, MI 49002
(269) 329-4422

Judy Graham
Utility Contract Administrator
City of Portage
7719 South Westnedge Avenue
Portage, MI 49002
(269) 329-4424

John Rydbeck
Project Manager
Veolia
7701 South Westnedge Avenue
Portage, MI 49002
(269) 324-9235

The Portage City Council meets twice monthly on Tuesdays at 6 PM in Council Chambers at Portage City Hall (7900 South Westnedge Avenue).

As indicated in the water monitoring results on the following pages, the city water system had no Maximum Contaminant Level (MCL) violations during 2025. Through monitoring and testing, some substances have been detected; however, the concentrations found are well below the regulatory standards and not harmful to customers.

The MCL established for each substance is set by the EPA at a very stringent level. To understand the possible health effects described for many regulated substances, a person would have to drink two liters of water containing the substance at the MCL every day for a lifetime to have a one-in-a-million chance of having the described health effect.

The City of Portage has completed an inventory of the 15,000 water service lines in the water system and found no lead water service lines. Lead can cause serious health effects in people of all ages, especially pregnant people, infants (both formula-fed and breast-fed), and young children. Lead in drinking water is primarily from materials and parts used in service lines and in home plumbing. The City of Portage is responsible for providing high-quality drinking water and removing lead pipes but cannot control the variety of materials used in plumbing in your home. Because lead levels may vary over time, lead exposure is possible even when your tap sampling results do not detect lead at one point in time. You can help protect yourself and your family by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Using a filter, certified by an American National Standards Institute accredited

certifier to reduce lead, is effective in reducing lead exposures. Following the instructions provided with the filter to ensure the filter is used properly. Use only cold water for drinking, cooking and making baby formula. Boiling water does not remove lead from water. Before using tap water for drinking, cooking, or making baby formula, flush your pipes for several minutes. You can do this by running your tap, taking a shower, doing laundry or a load of dishes. If you have a lead service line or galvanized requiring replacement service line, you may need to flush your pipes for at least 5 minutes to flush water from both your home plumbing and the lead service line. If you are concerned about lead in your water and wish to have your water tested, contact Veolia, the City of Portage water operator, at 269-324-9235 for available resources. Information on lead in drinking water, testing methods and steps you can take to minimize exposure is available at <https://www.epa.gov/safewater/lead>.

Some people may be more vulnerable to substances in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders and some elderly and infants, can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. The Center for Disease Control (CDC) may be contacted at (800) 342-2437. Guidelines on appropriate means to lessen the risk of infection by microbiological substances are also available from the EPA Safe Drinking Water Hotline at (800) 426-4791.

Protecting Our Groundwater Source

The Michigan Department of Environment, Great Lakes and Energy (EGLE) performed source water assessments of all public water supplies to assess their susceptibility to contamination in 2003. The susceptibility rating, primarily based on geologic sensitivity and sources of contamination, uses a six-tiered scale from very low to very high. Based on the evaluation criteria, the assessment performed by EGLE rated the susceptibility of the ten City of Portage well sites as high. Questions regarding the Source Water Assessment may be directed to staff listed on the front page of this report.

The city has taken proactive steps to protect the groundwater, including the city's Wellhead Protection Program, Risk & Resilience Assessment, Stormwater Management Plan, Mandatory Sanitary Sewer Connection Program, Consolidated Drain Regional Stormwater Facility, and South Westnedge Avenue Stormwater Treatment Enhancement Project.

The 2021 updated **Wellhead Protection Program** helps identify sources of pollution that could potentially impact the groundwater supply. The program delineates measures that protect the groundwater from contamination. The **Risk & Resilience Assessment** also completed in 2021 evaluates the threats, vulnerabilities, and consequences of potential hazards. Strategies, plans, procedures, and resources to improve resilience were implemented.

The **Stormwater Management Plan** is a proactive plan developed to protect city groundwater resources. The plan defines the method of stormwater disposal in relation to the proximity of well sites or groundwater use. While it may impose additional cost to developments and businesses in Portage, the plan is a valuable tool used to protect the groundwater source from surface water runoff in commercial and industrial areas.

The **Mandatory Sewer Connection Program** eliminates the use of septic tanks and drain fields for wastewater disposal, as sanitary sewer service is made available. This helps eliminate the potential for groundwater contamination due to substances in the wastewater. As a result of this important program, more than 90 percent of all Portage residents utilize the city sanitary sewer system.

The **Consolidated Drain Regional Stormwater Facility** treats stormwater runoff from nearby commercial properties by removing sediment, grit, fertilizer, and other pollutants resulting in much cleaner water being discharged to Portage Creek.

The **South Westnedge Stormwater Treatment Enhancement Project** treats stormwater runoff from South Westnedge Avenue between West Centre Avenue and Garden Lane. The project eliminated direct stormwater discharges into Portage Creek resulting in much cleaner water discharged into Portage Creek.

Water Monitoring Terms

The Water Monitoring Results shown in the tables may contain terms and abbreviations you might not be familiar with. To help you better understand these terms, the following definitions are provided:

Action Level (AL) - the concentration of a substance which, if exceeded, triggers treatment or other requirements which a water system must follow.

Detect (D) - laboratory analysis indicates the substance is present.

Maximum Contaminant Level (MCL) - the highest level of a substance that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - the level of a substance in drinking water below which there is no known or expected risk to health. MCLGs allow for an extra margin of safety.

Maximum Residual Disinfection Level (MRDL) - the highest

level of a disinfectant allowed in drinking water. There is convincing evidence that the addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfection Level Goal (MRDLG) - the level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Non-Detect (ND) - laboratory analysis indicates that the constituent is not present.

Parts per million (ppm) or Milligrams per liter (mg/L) - one part per million corresponds to one minute in two years, or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter (ug/L) - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Picocuries per liter (pCi/L) - picocuries per liter is a measure of the radioactivity in water.

Likely source of substance - if detected, where a substance may come from.

Per- and Polyfluoroalkyl Substances

Per- and polyfluoroalkyl substances, commonly known as PFAS, are contaminants of emerging concern. In 2020, EGLE established maximum contaminant levels (MCLs) and sampling requirements for seven PFAS compounds. PFAS are a large group of human-made chemicals that are fire resistant and

repel oil, stains, grease, and water. They have been widely used fire-fighting foams, stain repellents, nonstick cookware, waterproof clothing and shoes, fast food wrappers, personal care products and many other consumer goods. PFAS chemicals are very persistent, meaning that they do not easily break down in the environment. The sampling and test results for Portage are shown in the table below.

Per- and Polyfluoroalkyl Substances (PFAS)

Substance	Violation Yes/No	Highest Detected Level	Range Detected	Unit of Measurement	Year Sampled	Maximum Contaminant Level Goal	Maximum Contaminant Level	Likely Source of Substance
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)	No	Non-Detect	Non-Detect	Parts per trillion	2025	N/A	370 ppt	Discharge and waste from industrial facilities utilizing the Gen X Chemical process
Perfluorobutane Sulfonic Acid (PFBS)	No	7.7 ppt	Non-Detect to 7.7 ppt	Parts per trillion	2025	N/A	420 ppt	Discharges and waste from industrial facilities; stain-resistant treatments
Perfluorohexane Sulfonic Acid (PFHxS)	No	5.0 ppt	Non-Detect to 5.0 ppt	Parts per trillion	2025	N/A	51 ppt	Firefighting foam; discharges and waste from industrial facilities
Perfluorohexanoic Acid (PFHxA)	No	Non-Detect	Non-Detect	Parts per trillion	2025	N/A	400,000 ppt	Firefighting foam; discharges and waste from industrial facilities
Perfluorononanoic Acid (PFNA)	No	Non-Detect	Non-Detect	Parts per trillion	2025	N/A	6 ppt	Firefighting foam; discharges and waste from industrial facilities
Perfluorooctane Sulfonic Acid (PFOS)	No	Non-Detect	Non-Detect	Parts per trillion	2025	N/A	16 ppt	Firefighting foam; discharges and waste from industrial facilities
Perfluorooctanoic Acid (PFOA)	No	Non-Detect	Non-Detect	Parts per trillion	2025	N/A	8 ppt	Discharge and waste from industrial facilities, stain-resistant treatments

Unregulated Contaminants

Substance	Highest Level Detected	Range Detected	Unit of Measurement	Year Sampled	Likely Source of Substance	Health Effects
Sodium	75 ppm	11 ppm to 75 ppm	Parts per million	2025	Naturally present in the environment	N/A

Annual Water Monitoring Results									
Inorganic Substances									
Substance	Violation Yes/No	Highest Level Detected	Range Detected	Unit of Measurement	Year Sampled	Maximum Contaminant Level Goal	Maximum Contaminant Level	Likely Source of Substance	
Fluoride	No	0.82 ppm	0.36 ppm to 0.82 ppm	Parts per million	2025	4 ppm	4 ppm	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories	
Nitrate (As Nitrogen)	No	2.3 ppm	Non-Detect to 2.3 ppm	Parts per million	2025	10 ppm	10 ppm	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits	
Arsenic	No	3.0 ppb	Non-Detect to 3 ppb	Parts per billion	2025	0 ppb	10 ppb	Erosion of natural deposits; Runoff from orchards, and glass and electronics production wastes	
Radioactive Substances									
Substance	Violation Yes/No	Highest Level Detected	Range Detected	Unit of Measurement	Year Sampled	Maximum Contaminant Level Goal	Maximum Contaminant Level	Likely Source of Substance	
Alpha Emitters	No	2.51 pCi/L	Non-Detect to 2.51 pCi/L	Picocuries per liter	2023	0 pCi/L	15 pCi/L	Erosion of natural deposits	
Radium 226 & 228	No	1.189 pCi/L	0.407 pCi/L to 1.189 pCi/L	Picocuries per liter	2023	0 pCi/L	5 pCi/L	Erosion of natural deposits	
Uranium	No	0.30 ppb	Non-Detect to 0.30 ppb	Parts per billion	2024	0 ppb	30 ppb	Erosion of natural deposits	
Disinfection Byproduct Monitoring									
Substance	Violation Yes/No	Range Detected	Highest Level Detected	Unit of Measurement	Year Sampled	Maximum Contaminant Level Goal	Maximum Contaminant Level	Likely Source of Substance	
Total Trihalomethane (TTHM)	No	27.0 ppb to 42.0 ppb	42.0 ppb	Parts per billion	2025	N/A	80 ppb	Byproduct of drinking water disinfection	
Haloacetic Acids (HAA5s)	No	12.0 ppb to 23.0 ppb	23.0 ppb	Parts per billion	2025	N/A	60 ppb	Byproduct of drinking water disinfection	
Substance	Violation Yes/No	Range Detected	Running Annual Average	Unit of Measurement	Year Sampled	Maximum Disinfection Residual Level Goal	Maximum Disinfection Residual Level	Likely Source of Substance	
Chlorine Residual	No	0.26 ppm to 0.44 ppm	0.31 ppm	Parts per million	2025	4 ppm	4 ppm	Water additive used to control microbes	
Lead and Copper Monitoring									
Substance	Violation Yes/No	Level Detected at 90th Percentile	Range Detected	Unit of Measurement	Year Sampled	Number of Samples Above Action Level	Maximum Contaminant Level Goal	Action Level	Likely Source of Substance
Lead	No	2.0 ppb	0 ppb to 18 ppb	Parts per billion	2023	1	0.0 ppb	15 ppb	Lead service lines, corrosion of household plumbing including fittings and fixtures; Erosion of natural deposits.
Copper	No	0.7 ppm	0 ppm to 1.7 ppm	Parts per million	2023	1	1.3 ppm	1.3 ppm	Corrosion of household plumbing systems; Erosion of natural deposits.

There is no safe level of lead in drinking water. Exposure to lead in drinking water can cause serious health effects in all age groups. Infants and children can have decreases in IQ and attention span. Lead exposure can lead to new learning and behavior problems or exacerbate existing learning and behavior problems. The children of persons who are exposed to lead before or during pregnancy can have increased risk of these adverse health effects. Adults can have increased risks of heart disease, high blood pressure, kidney, or nervous system problems. Copper is an essential nutrient, but some people who drink water containing copper in excess of the action level over a relatively short amount of time could experience gastrointestinal distress. Some people who drink water containing copper in excess of the action level over many years could suffer liver or kidney damage. People with Wilson's Disease should consult their personal doctor.